


Darby Roof Company October 15  
th 2008 1300 hours Highline  
Meadows- Repair of roof  
Townhome #521  
Improper Roof Repair Techniques





Unit 521 Roof Repair by Darbt  
Roof October 15th 2008



Darby Roof using this on Debrigum Roof with Rubber cement- Not approved for use on Derbigum Roofs- Only last 3 Months to One Years and then leaks again-Source Owens Corning 10 15 2008



\



Henry Elastic Cement used to patch  
Derbigum roof- Incorrect Patching  
Method by Dary Roofing

