

Your e-mail to Owens Corning Directors has been forwarded to me for handling. The Condominiums at Highline Meadows Subdivision in Littleton, Colorado were covered by an Owens Corning Derbigum Roofing Guaranty. This roof was completed on May 15, 1985.

The installed roof was an IS-RU. This is a recover specification where the gravel was removed from an existing built-up roofing system. The roof was primed and one layer of Derbigum SP was torched to the surface. This is a 10 year specification and a 10 year guarantee was issued.


In late 1989, Owens Corning discovered that the reinforcing mat was showing through the roof surface. Owens Corning decided to apply a 2nd layer of SP to resolve the issue. In 1990 we hired Bacon & Schramm to do this work.

The 2 ply system would repair the problem and result in a superior roof as there are 2 plies of roofing with double redundancy and twice the tensile strength.

After the installation of this repair, we were called with 5 service requests. One in 1991, 2 in 1992 and 2 in 1993. There have been no requests for service since that date.

This roof was covered by a 10-year guaranty that expired 13.3 years ago. Accordingly, we will be taking no further action on this matter.

Regards,



Michael J. DeWit
Mgr., Commercial Roofing

/dr